

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAT577		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KAREN SCHRAMSKI Phone # (612)817-2255						1. Well Location				Fire # (if avail.)	
Mailing Address 1290 208TH ST						Town of ST. CROIX FALLS					
City ST. CROIX State WI Zip Code 54024						Street Address or Road Name and Number 1290 208TH ST					
County Polk		Co. Permit # w		Notification # 8822238601		Completed 06-21-2022		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) TRAUT MARK J WELLS INC				Lic. # 5912		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.3956 °N -92.5848 °W		Method Code GPS008	
Address 32640 COUNTY RD 133 SAINT JOSEPH MN 56374				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 34 34 N 18 W		2. Well Type Replacement of previous unique well # N/A constructed in Reason for replaced or reconstructed well ? RELOCATED WELL			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Construction Type Drilled					
3. Well serves 1 # of BUSINESS Non-community Drillhole				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
Heat Exchange ___ # of drillholes											
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) 8		From (ft.) Surface		To (ft.) 86		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
						Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T M C T-TAN/BROWN M-MEDIUM C-CLAY Surface 57 T S S T-TAN/BROWN S-SOFT/LOOSE S-SAND 57 59 T M C T-TAN/BROWN M-MEDIUM C-CLAY 59 68 G H C G-GRAY H-HARD/FIRM C-CLAY 68 82 T S S T-TAN/BROWN S-SOFT/LOOSE S-SAND 82 86 K H K K-BLACK H-HARD/FIRM K-COBBLER/BOULDERS 86 86	
6. Casing, Liner, Screen											
Dia. (in.) 4		Material, Weight, Specification Manufacturer & Method of Assembly PVC, SDR 21, ASTM F480 1.92LBS/FT, WEST LAKE, GLUED BELLED END				From (ft.) Surface		To (ft.) 82		11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.) 4		Screen type, material & slot size STAINLESS STEEL JOHNSON 4"TEL				From (ft.) 82		To (ft.) 86			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material EZ SEAL		From (ft.) Surface		To (ft.) 72		# Sacks Cement 7 S		12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes			
13. Constructor / Supervisory Driller								Lic #		Date Signed	
MJT								5911		06-21-2022	
Drill Rig Operator								Lic or Reg #		Date Signed	
PS											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50
			Sewer - Building Sanitary	>	8

Comment: NOTIFICATON #8822238601. WAS PURCHASED UNDER ST CROIX COUNTY AND NEEDS TO BE CHANGED TO POLK COUNTY.

Created On: 09-08-2022**Updated On:** 04-27-2023**Review Status:** APPROVED