Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAU736

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: ZIMMERMAN, SCOTT	Phone #
Mailing Address: N5651 SHEA LANE	
City: ALBANY	State: WI — Zip Code: 53502
County: Adams	Co. Permit #: — Notification #: 8885444301 — Completed: 09-13-2022
Well Constructor (Business Name): FOSTER'S SEPTIC & WELL SERVICE LLC	Lic. #: 163 — Facility ID # (Public Wells):
Address: 2520 STATE RD 13, ADAMS WI 53910-9739	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of PRESTON	Fire # (if avail.): 1057
Street Address or Road Name and Number: 1057 CZECH LANE	
Subdivision Name: EYEFULL ACRES NORTH SHORE	Lot #: 14 — Block #: 1
Latitude / Longitude in Decimal Degree (DD): 43.9834 °N -89.7888 °W	Method Code: GPS008
SE SW or Govt Lot #: — Section: 33 — Township: 18 N — Range: 6 E	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of PROPOSED HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	68

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	25
C	C-CLAY	25	48
S	S-SAND	48	68

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESTLINE ASTM F-480 200 PSI SDR21	Surface	65
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	ALLOY MACHINE SS 15 SLOT	65	68

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENT	Surface	57	7 S
RED FLINT # 40	57	68	4 S

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	09-13-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ZF	8506	09-13-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		45	Septic or Holding, or POWTS Tank		35

Comment:

Variance ID	Variance or Exception Type	Date	Reason
32449	Separation Distance Variance	09/08/2022	LESS THAN 50' FROM POWTS

Created On: 08-30-2022 Updated On: 10-15-2026 Review Status: APPROVED