

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAU736		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner ZIMMERMAN, SCOTT						Phone #															
Mailing Address N5651 SHEA LANE						1. Well Location						Fire # (if avail.)									
City ALBANY						State WI		Zip Code 53502				Town of PRESTON		1057							
Street Address or Road Name and Number						1057 CZECH LANE															
County Adams		Co. Permit #		Notification # 8885444301		Completed 09-13-2022		Subdivision Name EYEFULL ACRES NORTH SHORE				Lot # 14		Block # 1							
Well Constructor (Business Name) FOSTER'S SEPTIC & WELL SERVICE LLC				Lic. # 163		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9834 °N -89.7888 °W				Method Code GPS008							
Address 2520 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #				SE SW		Section 33		Township 18 N		Range 6 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0				2. Well Type New Well													
3. Well serves 1 # of PROPOSED HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No				of previous unique well # constructed in											
						Hicap Property ? No				Reason for replaced or reconstructed well ?											
						Hicap Potable ? No				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		68		Yes Rotary - Mud Circulation				No		S		S-SAND		Surface		25			
						No Rotary - Air				No		C		C-CLAY		25		48			
						No Rotary - Air & Foam				No		S		S-SAND		48		68			
						No Drill-Through Casing Hammer															
						No Reverse Rotary															
						No Cable-tool Bit ___ in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. below ground surface				15 in. above grade							
4		CRESTLINE ASTM F-480 200 PSI SDR21				Surface		65		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 55 ft. below surface				Disinfected ? Yes							
4		ALLOY MACHINE SS 15 SLOT				65		68		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Airlift											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes							
Method TREMIE PIPE - PUMPED														Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
HIGH SOLIDS BENT				Surface		57		7 S													
RED FLINT # 40				57		68		4 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RR				7202		09-13-2022	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														ZF				8506		09-13-2022	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		45	Septic or Holding, or POWTS Tank		35

Comment:

Variance ID	Variance or Exception Type	Date	Reason
32449	Separation Distance Variance	09/08/2022	LESS THAN 50' FROM POWTS

Created On: 08-30-2022

Updated On: 09-03-2024

Review Status: APPROVED