Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAU742

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RITCHIE, KURT	Phone #
Mailing Address: 201 HUNTERS CROSSINGS BLVD #202-10	
City: BASTROP	State: TX — Zip Code: 78602
County: Adams	Co. Permit #: — Notification #: 8899332602 — Completed: 09-13-2022
Well Constructor (Business Name): FOSTER'S SEPTIC & WELL SERVICE LLC	Lic. #: 163 — Facility ID # (Public Wells):
Address: 2520 STATE RD 13, ADAMS WI 53910-9739	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of ADAMS			Fire # (if avail.): 2311
Street Address or Road Name and Number: 2311 13TH LN			
Subdivision Name: PINE OAKS SUB		Lot #: 6	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9217 °N -89.832 °W			Method Code: GPS008
NE NW or Govt Lot #:	Section: 30	Township: 17 N	Range: 6 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of RV
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	30
C	C-CLAY	30	52
S	S-SAND	52	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESTLINE ASTM F-480 200 PSI SDR21	Surface	55
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	ALLOY MACHINE SS 15 SLOT	55	58

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENT	Surface	49	6 S
RED FLINT # 40	49	58	4 S

9. Static Water Level
22 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	09-13-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ZF	8506	09-13-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 09-14-2022 Updated On: 09-23-2022 Review Status: APPROVED