Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAU743

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	DASE, KEITH
Phone #	
Mailing Address	1546 COUNTY ROAD J
City	FRIENDSHIP
State	WI
Zip Code	53934
County	Adams
Co. Permit #	
Notification #	8906954001
Completed	09-19-2022
Well Constructor (Business Name)	FOSTER'S SEPTIC & WELL SERVICE LLC
Lic. #	163
Facility ID # (Public Wells)	
Address	2520 STATE RD 13 ADAMS WI 53910-9739
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.8

1. Well Location

Town of ADAMS	Fire # (if avail.) 1546
Street Address or Road Name and Number	1546 CTY RD J
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.974 °N -89.8673 °W
Method Code	GPS008
SW NE or Govt Lot #	
Section	2
Township	17 N
Range	5 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NO WATER

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	61

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	6
		C		C-CLAY	6	28
		S		S-SAND	28	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESTLINE ASTM F-480 200 PSI SDR21	Surface	58
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	ALLOY MACHINE SS 15 SLOT	58	61

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENT	Surface	52	7 S
RED FLINT # 40	52	61	4 S

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	09-19-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ZF	8506	09-19-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Septic or Holding, or POWTS Tank		61

Comment:

Created On: 09-19-2022 Updated On: 10-15-2026 Review Status: APPROVED