

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAU743				Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DASE, KEITH						Phone #									
Mailing Address 1546 COUNTY ROAD J						Town of ADAMS						Fire # (if avail.) 1546			
City FRIENDSHIP						State WI		Zip Code 53934							
County Adams		Co. Permit #		Notification # 8906954001		Completed 09-19-2022		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) FOSTER'S SEPTIC & WELL SERVICE LLC				Lic. # 163		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.974 °N -89.8673 °W				Method Code GPS008	
Address 2520 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 2 17 N 5 E		2. Well Type Replacement of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ? NO WATER									
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8		Surface		61		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
S		S-SAND						Surface		6					
C		C-CLAY						6		28					
S		S-SAND						28		61					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		CRESTLINE ASTM F-480 200 PSI SDR21				Surface		58							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		ALLOY MACHINE SS 15 SLOT				58		61							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
HIGH SOLIDS BENT				Surface		52		7 S							
RED FLINT # 40				52		61		4 S							
9. Static Water Level															
25 ft. below ground surface															
10. Pump Test															
Pumping level 45 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
RR				7202		09-19-2022									
Drill Rig Operator				Lic or Reg #		Date Signed									
ZF				8506		09-19-2022									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Septic or Holding, or POWTS Tank		61

Comment:

Created On: 09-19-2022

Updated On: 09-30-2022

Review Status: APPROVED