Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAV588

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SAMUEL ALLGYER	Phone #
Mailing Address: 18903 COUNTY ROAD G	
City: BELMONT	State: WI — Zip Code: 53510
County: Lafayette	Co. Permit #: — Notification #: 8990131501 — Completed: 12-05-2022
Well Constructor (Business Name): NIFFENEGGER WELL & PUMP INC	Lic. #: 6295 — Facility ID # (Public Wells):
Address: 902 2ND ST, MONROE WI 53566	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of KENDALL

Fire # (if avail.):

Street Address or Road Name and Number: NORTH LANE ROAD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.7259 °N -90.2456 °W — Method Code: GPS008

NW	NW	Section	Township	Range
or Govt Lot #		22	3 N	2 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME, FARM

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
12	Surface	8
8.625	8	118.5
6	118.5	270

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 8depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97'/FT, ASTM A53B, EXL-TUBE, WELDED JOINTS	Surface	118.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	118.5	60 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	C		T-TAN/BROWN M-MEDIUM C-CLAY	Surface	4
Y	M	L		Y-YELLOW M-MEDIUM L-LIMESTONE/DOLOMITE	4	95
T	M	L		T-TAN/BROWN M-MEDIUM L-LIMESTONE/DOLOMITE	95	105
U	M	L		U-BLUE M-MEDIUM L-LIMESTONE/DOLOMITE	105	135
U	H	L		U-BLUE H-HARD/FIRM L-LIMESTONE/DOLOMITE	135	192
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	192	270

9. Static Water Level	11. Well Is	
182 ft. below ground surface	18 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 190 ft. below surface	Disinfected ?	Yes
Pumping at 10 GP M for 1 Hrs.	Capped ?	Yes
Pumping Method ? Airlift		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN	332	12-13-2022
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Animal Barn or Barn Pen	>	90	Septic or Holding, or POWTS Tank	>	90

Comment:

Created On: 12-13-2022 Updated On: 10-15-2026 Review Status: APPROVED