

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAX325		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner BRUNGRABER, KEVIN				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 6309 SHAUGHNESSY LANE				City PHELPS		State WI		Zip Code 54521		Town of PHELPS	
County Vilas				Co. Permit #		Notification # 9257412001		Completed 09-07-2023		Street Address or Road Name and Number SHAUGHNESSY LANE	
Well Constructor (Business Name) HARTMAN WELL DRILLING & PUMP SERVICES INC				Lic. # 8778		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.1482 °N -89.156 °W		Method Code GPS008	
Address 5900 ROBIN DR EAGLE RIVER WI 54521				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 5 42 N 11 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 1		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?			
Private, potable				Hicap Potable ? No		Construction Type Drilled		Heat Exchange ___ # of drillholes			
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		34		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)			Geology Codes T S T-TAN/BROWN S-SAND		
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology Type, Caving/Noncaving, Color, Hardness, etc...	
6		6" 280 WALL 20' BLK PE				Surface		31		From (ft.) To (ft.) Surface 34	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
6		SS 10 SLOT				31		34		30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface		10		1 S			
9. Static Water Level											
8 ft. below ground surface											
10. Pump Test											
Pumping level 20 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ? Airlift											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
JZ				Lic # 7837		Date Signed 03-14-2024		Drill Rig Operator JZ Lic or Reg # 7837 Date Signed 03-14-2024			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 09-07-2023

Updated On: 05-22-2024

Review Status: APPROVED