

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAX329		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ROLLINS PATRICK (CORNERSTONE)						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 4216 LAKE AIDEN RD								Town of SUGAR CAMP				4216					
City SUGAR CAMP						State WI		Zip Code 54521				Street Address or Road Name and Number LAKE AIDEN RD					
County Oneida		Co. Permit #		Notification # 9279494901		Completed 10-04-2023		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) HARTMAN WELL DRILLING & PUMP SERVICES INC				Lic. # 8778		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8778 °N -89.3402 °W				Method Code GPS008					
Address 5900 ROBIN DR EAGLE RIVER WI 54521				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 11 39 N 9 E		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 1		Reason for replaced or reconstructed well ?				Construction Type Drilled					
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		62		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				Y S		Y-SAND & GRAVEL T-TAN/BROWN S-SAND		Surface 50		50 62	
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface		20 in. above grade					
6		280 ASTM A53B 18.97# WELD JT WHEATLAND				Surface		58		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Airlift							
6		JOHNSON 10 SLOT				58		62									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No			
Method MOUNDED												Filled & Sealed Well(s) as needed?		No			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller		Lic #		Date Signed			
GRANULAR BENTONITE				Surface		25		1 S		JZ		7837		10-19-2023			
												Drill Rig Operator		Lic or Reg #		Date Signed	
												JZ		7837		10-19-2023	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 10-05-2023

Updated On: 10-30-2023

Review Status: APPROVED