Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAX329

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROLLINS PATRICK (CORNERSTONE)	Phone #
Mailing Address: 4216 LAKE AIDEN RD	
City: SUGAR CAMP	State: WI — Zip Code: 54521
County: Oneida	Co. Permit #: — Notification #: 9279494901 — Completed: 10-04-2023
Well Constructor (Business Name): HARTMAN WELL DRILLING & PUMP SERVICES INC	Lic. #: 8778 — Facility ID # (Public Wells):
Address: 5900 ROBIN DR, EAGLE RIVER WI 54521	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1	

1. Well Location

Town of SUGAR CAMP	Fire # (if avail.): 4216
Street Address or Road Name and Number: LAKE AIDEN RD	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.8778 °N -89.3402 °W — Method Code: GPS008	
NW SW or Govt Lot #: — Section: 11 — Township: 39 N — Range: 9 E	

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	62

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	50
T		S		T-TAN/BROWN S-SAND	50	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	280 ASTM A53B 18.97# WELD JT WHEATLAND	Surface	58
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON 10 SLOT	58	62

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	25	1 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JZ	7837	10-19-2023
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JZ	7837	10-19-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 10-05-2023 Updated On: 10-30-2023 Review Status: APPROVED