Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAX522

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, CARL			Phone #
Mailing Address: W7392 HWY 70			
City: SPOONER	State: WI	Zip Code: 54801	
County: Washburn	Co. Permit #:	Notification #: 8995096701	Completed: 12-12-2022

Well Constructor (Business Name): BEECROFT, JEREMY R	Lic. #: 6457	Facility ID # (Public Wells):	
Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 12.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of EVERGREEN | Fire # (if avail.): W7392

Street Address or Road Name and Number: HWY 70

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.8226 °N -91.9116 °W | Method Code: GPS008

SE or Govt Lot #	NE	Section	Township	Range
		36	39 N	13 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
SLOW POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	74

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC CASING WELDED ASTM F480	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	15 SLOT SS SCREEN	69	74

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	65	6 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 75 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	12-12-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF	8979	12-12-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 12-13-2022 Updated On: 06-28-2023 Review Status: APPROVED