

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAX522		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHNSON, CARL						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address W7392 HWY 70						Town of EVERGREEN						W7392							
City SPOONER						State WI		Zip Code 54801				Street Address or Road Name and Number HWY 70							
County Washburn		Co. Permit #		Notification # 8995096701		Completed 12-12-2022		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BEECROFT, JEREMY R				Lic. # 6457		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8226 °N -91.9116 °W				Method Code GPS008					
Address JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801				Well Plan Approval #				SE NE		Section 36		Township 39 N		Range 13 W					
				Approval Date (mm-dd-yyyy)				or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 12.5		2. Well Type Replacement				of previous unique well #				constructed in					
						Reason for replaced or reconstructed well ? SLOW POINT													
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		74		Yes Rotary - Mud Circulation		No		Y		Y-SAND & GRAVEL		Surface		74			
						No Rotary - Air		No											
						No Rotary - Air & Foam		No											
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				18 in. above grade					
5		SDR17 PVC CASING WELDED ASTM F480				Surface		69		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 25 ft. below surface				Disinfected ? Yes					
5		15 SLOT SS SCREEN				69		74		Pumping at 75 GP M for 1 Hrs.				Capped ? Yes					
7. Grout or Other Sealing Material												Pumping Method ? Airlift							
Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ?				Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
EZ SEAL				Surface		65		6 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JB				6457		12-12-2022	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												JF				8979		12-12-2022	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 12-13-2022

Updated On: 06-28-2023

Review Status: APPROVED