

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAX523		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HILL CONSTRUCTION						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 15988 US HWY 63						Town of SAND LAKE						6182									
City HAYWARD						State WI		Zip Code 54843				Street Address or Road Name and Number BREEZY POINT LANE									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Sawyer				9046296801		02-08-2023															
Well Constructor (Business Name) BEECROFT, JEREMY R				Lic. # 6457		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8598 °N -91.4448 °W				Method Code GPS008							
Address JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801				Well Plan Approval #				NW SE		Section 14		Township 39 N		Range 9 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well				of previous unique well #		constructed in					
3. Well serves 1 # of HOME				Hicap Well ? No				Reason for replaced or reconstructed well ?													
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No																	
Construction Type Drilled																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		117		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						A Z A-COARSE Z-CLAY & GRAVEL A Y A-COARSE Y-SAND & GRAVEL		Surface 110		110 117					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				18 in. above grade							
5		SDR17PVC CASING WELDED ASTM F480				Surface		112		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 55 ft. below surface				Disinfected ? Yes							
5		15 SLOT SS SCREEN				112		117		Pumping at 40 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ? Airlift				12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No			
Method TREMIE PIPE - PUMPED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
EZ SEAL				Surface		108		9 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														JB				6457		02-08-2023	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														JF				8979		02-08-2023	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		85	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-09-2023

Updated On: 06-26-2023

Review Status: APPROVED