Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: AAX523

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HILL CONSTRUCTION	Phone #
Mailing Address: 15988 US HWY 63	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #: — Notification #: 9046296801 — Completed: 02-08-2023
Well Constructor (Business Name): BEECROFT, JEREMY R	Lic. #: 6457 — Facility ID # (Public Wells):
Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.7

1. Well Location

Town of SAND LAKE	Fire # (if avail.): 6182
Street Address or Road Name and Number: BREEZY POINT LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8598 °N -91.4448 °W	Method Code: GPS008
NW SE or Govt Lot #:	Section: 14 — Township: 39 N — Range: 9 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	117

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	A	Z		A-COARSE Z-CLAY & GRAVEL	Surface	110
	A	Y		A-COARSE Y-SAND & GRAVEL	110	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17PVC CASING WELDED ASTM F480	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	15 SLOT SS SCREEN	112	117

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	108	9 S

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	02-08-2023
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF	8979	02-08-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		85	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-09-2023 Updated On: 10-15-2026 Review Status: APPROVED