Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAX524

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SHERMAN BUILDERS	Phone #
Mailing Address: 2244 HWY 65	
City: MORA	State: MN Zip Code: 55051
County: Burnett	Co. Permit #:	Notification #: 9048582201	Completed: 02-13-2023
Well Constructor (Business Name): BEECROFT, JEREMY R	Lic. #: 6457	Facility ID # (Public Wells):
Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4.5

1. Well Location

Town of UNION	Fire # (if avail.): 27722
Street Address or Road Name and Number: YELLOW LAKE RD	
Subdivision Name:	Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9207 °N -92.4249 °W	Method Code: GPS008

NW	SW	Section	Township	Range
or Govt Lot #		25	40 N	17 W

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	107

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	59
X	X-SAND & CLAY	59	97
S	S-SAND	97	107

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17PVC CASING WELDED ASTM F480	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT SS SCREEN	102	107

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	95	8

9. Static Water Level
54 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 50 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	02-14-2023
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF	8979	02-14-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: THERE ARE NO CONTAMINATION SOURCES AT TIME OF WELL

Created On: 02-14-2023 Updated On: 10-15-2026 Review Status: APPROVED