Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAX525

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	FISCHER, JOHN
Phone #	
Mailing Address	15060 8TH. STREET N.
City	STILLWATER
State	MN
Zip Code	55082

County	Co. Permit #	Notification #	Completed
Polk		9109900607	04-18-2023

1. Well Location

Village of FREDERIC	Fire # (if avail.) 2624
Street Address or Road Name and Number	2624 68TH. STREET

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BEECROFT, JEREMY R	6457	

Latitude / Longitude in Decimal Degree (DD): 45.5852 °N -92.2999 °W
Method Code: GPS008

SW	SW	Section	Township	Range
or Govt Lot #		24	36 N	16 W

Well Plan Approval #

Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		4.4

Reason for replaced or reconstructed well ?
HIGH IRON

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	162

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		N-FINE S-SAND	Surface	60
		S		S-SAND	60	75
		X		X-SAND & CLAY	75	105
		X	C	X-SAND & CLAY C-CLAYEY	105	130
		X		X-SAND & CLAY	130	145
	S	N		S-SOFT/LOOSE N-SANDSTONE	145	162

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC CASING WELDED ASTM F480	Surface	157
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	15 SLOT SS SCREEN	157	162

9. Static Water Level
47 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 80 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	150	13 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	04-18-2023
Drill Rig Operator	Lic or Reg #	Date Signed
JF	8979	04-18-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-19-2023 Updated On: 08-28-2023 Review Status: APPROVED