

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAX525		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FISCHER, JOHN						Phone #									
Mailing Address 15060 8TH. STREET N.						1. Well Location						Fire # (if avail.)			
City STILLWATER						State MN		Zip Code 55082				Village of FREDERIC		2624	
County Polk		Co. Permit #		Notification # 9109900607		Completed 04-18-2023		Street Address or Road Name and Number				2624 68TH. STREET			
Well Constructor (Business Name) BEECROFT, JEREMY R						Lic. # 6457		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)		Method Code	
Address JEREMY BEECROFT WELL DRLG & PUMP REPAIR W7414 MILLER RD SPOONER WI 54801						Well Plan Approval #		SW SW		Section 24		Township 36 N		Range 16 W	
						Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 4.4				2. Well Type Replacement					
Reason for replaced or reconstructed well ?						HIGH IRON									
3. Well serves 1 # of HOME						Hicap Well ? No									
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		162		Yes Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
N		S		N-FINE S-SAND				Surface		60					
		S		S-SAND				60		75					
		X		X-SAND & CLAY				75		105					
		X		C		X-SAND & CLAY C-CLAYEY		105		130					
		X		X-SAND & CLAY				130		145					
S		N		S-SOFT/LOOSE N-SANDSTONE				145		162					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)							
5		SDR17 PVC CASING WELDED ASTM F480				Surface		157							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		15 SLOT SS SCREEN				157		162							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
EZ SEAL				Surface		150		13 S							
9. Static Water Level															
47 ft. below ground surface															
10. Pump Test															
Pumping level 65 ft. below surface															
Pumping at 80 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
JB				6457				04-18-2023							
Drill Rig Operator				Lic or Reg #				Date Signed							
JF				8979				04-18-2023							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-19-2023

Updated On: 08-28-2023

Review Status: APPROVED