

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAY579		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LEDERMAN, DAVID						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 11261 BROWN RD						Town of LITTLE RICE						11261			
City TOMAHAWK						State WI		Zip Code 54487				Street Address or Road Name and Number BROWN RD			
County Oneida		Co. Permit #		Notification # 9005059901		Completed 01-03-2023		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) RICHARDSON WD/ERTL ENTERPRISES INC				Lic. # 315		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.6077 °N -89.8144 °W				Method Code GPS008	
Address 10632 HWY 70 WEST MINOCQUA WI 54548				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 13 36 N 5 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology						
10.75 Surface 40			No Rotary - Mud Circulation No			Geology Codes Y Y-SAND & GRAVEL Surface 35			Type, Caving/Noncaving, Color, Hardness, etc...						
6 40 160			Yes Rotary - Air Yes			Q Q-GRANITE 35 160									
			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is			
6		BLK ASTM A53B; WELD 18.97 LBS.; PE IMPORT				Surface		40		15 ft. below ground surface		12 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes			
										Pumping level 100 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ? Test Pump					
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
NEAT CEMENT GROUT				Surface		40		8 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller															
TF				Lic # 8520		Date Signed 01-13-2023									
Drill Rig Operator				Lic or Reg # 8443		Date Signed 01-13-2023									
CM															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75	Septic or Holding, or POWTS Tank	=	60

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	01/24/2023	NOT HOOKED UP YET; ELECTRIC & TANK NOT IN YET

Created On: 01-24-2023

Updated On: 07-03-2023

Review Status: APPROVED