Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAY581

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHNEIDER, CHUCK	Phone #: (715)493-7141
Mailing Address: 8967 PARKSHORE DR	
City: MINOCQUA	State: WI — Zip Code: 54548
County: Oneida	Co. Permit #:
Notification #: 9033209501	Completed: 01-18-2023
Well Constructor (Business Name): RICHARDSON WD/ERTL ENTERPRISES INC	Lic. #: 315
Facility ID # (Public Wells):	
Address: 10632 HWY 70 WEST MINOCQUA WI 54548	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of HAZELHURST	Fire # (if avail.): 6027
Street Address or Road Name and Number: SCHNEIDER DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7562 °N -89.744 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 28 — Township: 38 N — Range: 6 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR21 PVC 200 PSI; ASTM D2241-F480; CRESLINE, GLUED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	ALLOY 12 SLOT SS	57	60

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT, 20% SOLIDS, 9.8 LBS.	Surface	52	6 S
#40 GRAVEL PACK RED FLINT	52	60	8 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	8520	01-20-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	70	Septic or Holding, or POWTS Tank	=	50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/02/2023	NOT HOOKED UP YET; ELECTRIC NOT IN

Created On: 02-02-2023 Updated On: 10-15-2026 Review Status: APPROVED