

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AA Y713		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner GOODE, GENE					Phone #		1. Well Location Fire # (if avail.) Town of WOLF RIVER 7344 Street Address or Road Name and Number 7322 CONLIN CT				
Mailing Address 410 SOUTH RIVER RD.											
City FREMONT			State WI		Zip Code 54940		Subdivision Name Lot # Block #				
County Winnebago		Co. Permit #		Notification # 9213054501		Completed 07-24-2023					
Well Constructor (Business Name) SCHAFFER R J & SONS INC				Lic. # 177		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.1576 °N -88.8747 °W		Method Code GPS008	
Address 520 WAUPACA ST FREMONT WI 54940				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 31 20 N 14 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock			
8.75		Surface		103		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T C		T-TAN/BROWN C-CLAY				Surface		4			
K U S		K-BLACK U-MUD OR MUCK S-SANDY				4		17			
T C		T-TAN/BROWN C-CLAY				17		80			
T X S		T-TAN/BROWN X-SAND & CLAY S-SANDY				80		89			
T S		T-TAN/BROWN S-SAND				89		103			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
5		CRESTLINE SDR21, PVC, ASTM F-480 SOLVENT WELD CASING				Surface		99			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
5		5X4X12 SLOT STAINLESS STEEL				99		103			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
QUICK GROUT		Surface		90		7 S					
GRAVEL PACK - RED FLINT SAND & GRAVEL		90		103		15 S					
9. Static Water Level 1 ft. below ground surface											
10. Pump Test Pumping level 10 ft. below surface Pumping at 15 GP M for 6.5 Hrs. Pumping Method ? Test Pump											
11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller		Lic #		Date Signed							
MAS		643		07-26-2023							
Drill Rig Operator		Lic or Reg #		Date Signed							
MAS		643		07-26-2023							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		18	Sewer - Collector - Sanitary		65

Comment:

Created On: 08-25-2023

Updated On: 08-25-2023

Review Status: APPROVED