Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAY714

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORGAN, TOM	Phone #
Mailing Address: N6302 ST. RD. 49	
City: WEYAUWEGA	State: WI Zip Code: 54983
County: Waushara	Co. Permit #:
Notification #: 9216662801	Completed: 08-07-2023
Well Constructor (Business Name): SCHAFER R J & SONS INC	Lic. #: 177
Facility ID # (Public Wells):	
Address: 520 WAUPACA ST FREMONT WI 54940	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.1	

1. Well Location

Town of BLOOMFIELD	Fire # (if avail.): N6302
Street Address or Road Name and Number: N6302 ST. RD. 49	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.2067 °N -88.9725 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 17 Township: 20 N Range: 13 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	161
6	161	195

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	Yes
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		T-TAN/BROWN C-CLAY	Surface	22
T		P	S	T-TAN/BROWN P-HARDPAN S-SANDY	22	138
T		Z		T-TAN/BROWN Z-CLAY & GRAVEL	138	150
I	Q	N		I-WHITE Q-CAVING N-SANDSTONE	150	157
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	157	195

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE NEW STEEL DRILLER'S PIPE 18.97 #/FT ASTM A-53 WHEATLAND TUBULAR	Surface	161
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 48 ft. below surface

Pumping at 15 GP M for 5.5 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROID QUICK GROUT	Surface	161	12 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MAS	643	08-14-2023
Drill Rig Operator	Lic or Reg #	Date Signed
MAS	643	08-14-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		48	POWTS dispersal component (soil absorption unit or mound)		59

Comment:

Created On: 08-25-2023 Updated On: 10-15-2026 Review Status: APPROVED