

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AA Y714		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MORGAN, TOM					Phone #			1. Well Location				Fire # (if avail.)							
Mailing Address N6302 ST. RD. 49								Town of BLOOMFIELD				N6302							
City WEYAUWEGA					State WI		Zip Code 54983		Street Address or Road Name and Number				N6302 ST. RD. 49						
County Waushara		Co. Permit #		Notification # 9216662801		Completed 08-07-2023		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) SCHAFFER R J & SONS INC					Lic. # 177		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.2067 °N -88.9725 °W				Method Code GPS008						
Address 520 WAUPACA ST FREMONT WI 54940					Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NE		Section 17		Township 20 N		Range 13 E				
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled												
3. Well serves 1 # of HOME					Hicap Well ? No														
Private, potable Drillhole					Hicap Property ? No														
Heat Exchange ___ # of drillholes					Hicap Potable ? No														
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)			From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)		
8.75			Surface		161		Yes Rotary - Mud Circulation		Yes		T C		T-TAN/BROWN C-CLAY		Surface		22		
6			161		195		No Rotary - Air		No		T P S		T-TAN/BROWN P-HARDPAN S-SANDY		22		138		
							No Rotary - Air & Foam		No		T Z		T-TAN/BROWN Z-CLAY & GRAVEL		138		150		
							No Drill-Through Casing Hammer				I Q N		I-WHITE Q-CAVING N-SANDSTONE		150		157		
							No Reverse Rotary				I H N		I-WHITE H-HARD/FIRM N-SANDSTONE		157		195		
							No Cable-tool Bit ___ in. dia...		No										
							No Dual Rotary		No										
							No Temp. Outer Casing ___ in. dia												
							No Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		34 ft. below ground surface				18 in. above grade					
6		PE NEW STEEL DRILLER'S PIPE 18.97 #/FT ASTM A-53 WHEATLAND TUBULAR				Surface		161		10. Pump Test				Developed ? Yes					
										Pumping level 48 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 5.5 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method BRADENHEAD																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
BAROID QUICK GROUT				Surface		161		12 S											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
MAS														643		08-14-2023			
Drill Rig Operator														Lic or Reg #		Date Signed			
MAS														643		08-14-2023			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		48	POWTS dispersal component (soil absorption unit or mound)		59

Comment:

Created On: 08-25-2023

Updated On: 08-25-2023

Review Status: APPROVED