

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAY720		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																	
Property Owner BUELOW, DUANE						Phone #																					
Mailing Address 5268 I-AH-MAYTAH RD						Town of SPRINGWATER						Fire # (if avail.) W5970															
City OSHKOSH						State WI		Zip Code 54901				Street Address or Road Name and Number W5970 ALP RD															
County Waushara		Co. Permit #		Notification # 9279928301		Completed 10-04-2023		Subdivision Name				Lot #		Block #													
Well Constructor (Business Name) SCHAFFER R J & SONS INC				Lic. # 177		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2328 °N -89.1803 °W				Method Code GPS008													
Address 520 WAUPACA ST FREMONT WI 54940				Well Plan Approval #		NE SW		Section 3		Township 20 N		Range 11 E		or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well																	
3. Well serves 1 # of GARAGE				Hicap Well ? No		of previous unique well # constructed in						Reason for replaced or reconstructed well ?															
Private, potable Drillhole				Hicap Property ? No		Heat Exchange ___ # of drillholes						Hicap Potable ? No															
Construction Type Drilled																											
4. Potential Contamination Sources - ON REVERSE SIDE																											
5. Drillhole Dimensions and Construction Method														8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
8.75		Surface		87		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								T S G		T-TAN/BROWN S-SAND G-W/GRAVEL/STONES				Surface		5					
														T K S		T-TAN/BROWN K-COBBLER/BOULDERS S-SANDY				5		29					
														T X		T-TAN/BROWN X-SAND & CLAY				29		52					
														T X U		T-TAN/BROWN X-SAND & CLAY U-MUDDY OR MURKY				52		71					
														T S		T-TAN/BROWN S-SAND				71		79					
														T A S		T-TAN/BROWN A-COARSE S-SAND				79		87					
6. Casing, Liner, Screen																											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)																			
5		CRESTLINE SDR21, PVC, ASTM F-480 SOLVENT WELD CASING				Surface		83																			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																			
5		5X4X15 SLOT STAINLESS STEEL				83		87																			
7. Grout or Other Sealing Material																											
Method TREMIE PIPE - PUMPED																											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement																			
BAROID QUIK GROUT				Surface		80		7 S																			
RED FLINT GRAVEL PACK				80		87		10 S																			

9. Static Water Level

39 ft. below ground surface

10. Pump Test

Pumping level 52 ft. below surface

Pumping at 45 GP M for 4 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

MAS

643

10-18-2023

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		106	Septic or Holding, or POWTS Tank		76

Comment:

Created On: 10-25-2023

Updated On: 11-08-2023

Review Status: APPROVED