Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAY720

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUELOW, DUANE	Phone #
Mailing Address: 5268 I-AH-MAYTAH RD	
City: OSHKOSH	State: WI — Zip Code: 54901
County: Waushara	Co. Permit #: — Notification #: 9279928301 — Completed: 10-04-2023
Well Constructor (Business Name): SCHAFER R J & SONS INC	Lic. #: 177 — Facility ID # (Public Wells):
Address: 520 WAUPACA ST, FREMONT WI 54940	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.5

1. Well Location

Town of SPRINGWATER	Fire # (if avail.): W5970
Street Address or Road Name and Number: W5970 ALP RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.2328 °N -89.1803 °W	Method Code: GPS008
NE SW or Govt Lot #:	Section: 3 — Township: 20 N — Range: 11 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of GARAGE

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	87

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	CRESTLINE SDR21, PVC, ASTM F-480 SOLVENT WELD CASING	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	5X4X15 SLOT STAINLESS STEEL	83	87

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROID QUIK GROUT	Surface	80	7 S
RED FLINT GRAVEL PACK	80	87	10 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S	G	T-TAN/BROWN S-SAND G-W/GRAVEL/STONES	Surface	5
T		K	S	T-TAN/BROWN K-COBBLES/BOULDERS S-SANDY	5	29
T		X		T-TAN/BROWN X-SAND & CLAY	29	52
T		X	U	T-TAN/BROWN X-SAND & CLAY U-MUDDY OR MURKY	52	71
T		S		T-TAN/BROWN S-SAND	71	79
T	A	S		T-TAN/BROWN A-COARSE S-SAND	79	87

9. Static Water Level	11. Well Is
39 ft. below ground surface	18 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 52 ft. below surface	Disinfected ? Yes
Pumping at 45 GP M for 4 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MAS	643	10-18-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		106	Septic or Holding, or POWTS Tank		76

Comment:

Created On: 10-25-2023 Updated On: 10-15-2026 Review Status: APPROVED