Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ221

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MATTINGLY, K & E BUILDERS	Phone #
Mailing Address: N1566 JOHANKNECHT LN	
City: WAUPACA	State: WI — Zip Code: 54981

County	Co. Permit #	Notification #	Completed
Waupaca	Wisconsin	8931289701	10-20-2022

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CULTON WATER WELLS & PUMP SERVICES	6895	

Address: 10898 CO RD T PO BOX 263 AMHERST WI 54405-0263

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		10

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of DAYTON	Fire # (if avail.) N1566

Street Address or Road Name and Number: N1566 JOHANKNECHT LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.2959 °N -89.1855 °W	GPS008

SE NE or Govt Lot #	Section	Township	Range
	17	21 N	11 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S	T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E NEW DRILLERS PIPE 18.97 LBS/FT ASTM A-53 WHEATLAND	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	5X48X12 STAINLESS STEEL TELESCOPTIC	40	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level
29 ft. below ground surface

10. Pump Test
Pumping level 31 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJC	6105	03-05-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		52

Comment:

Created On: 03-05-2023 Updated On: 07-07-2023 Review Status: APPROVED