

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAZ221		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MATTINGLY, K & E BUILDERS						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N1566 JOHANKNECHT LN						Town of DAYTON						N1566							
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number N1566 JOHANKNECHT LN							
County Waupaca		Co. Permit # Wisconsin		Notification # 8931289701		Completed 10-20-2022		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) CULTON WATER WELLS & PUMP SERVICES				Lic. # 6895		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.2959 °N -89.1855 °W				Method Code GPS008							
Address 10898 CO RD T PO BOX 263 AMHERST WI 54405-0263				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 17 21 N 11 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 10		Reason for replaced or reconstructed well ?				Construction Type Drilled							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		44		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						T S S		T-TAN/BROWN S-SOFT/LOOSE S-SAND		Surface		44	
6. Casing, Liner, Screen														8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 29 ft. below ground surface				11. Well Is 14 in. above grade					
6		P.E NEW DRILLERS PIPE 18.97 LBS/FT ASTM A-53 WHEATLAND				Surface		40		10. Pump Test Pumping level 31 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		5X48X12 STAINLESS STEEL TELESCOPIC				40		44											
7. Grout or Other Sealing Material Method MOUNDED														12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
GRANULAR BENTONITE				Surface				2 S											
13. Constructor / Supervisory Driller																			
RJC				Lic # 6105		Date Signed 03-05-2023													
Drill Rig Operator				Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		52

Comment:

Created On: 03-05-2023

Updated On: 07-07-2023

Review Status: APPROVED