Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ222

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: K & E BUILDERS	Phone #
Mailing Address: E2206 PARFREYVILLE RD	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: 8959726501 — Completed: 11-28-2022
Well Constructor (Business Name): CULTON WATER WELLS & PUMP SERVICES	Lic. #: 6895 — Facility ID # (Public Wells):
Address: 10898 CO RD T PO BOX 263 AMHERST WI 54405-0263	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 6.7

1. Well Location

Town of DAYTON	Fire # (if avail.): E2206
Street Address or Road Name and Number: E2206 PARFREYVILLE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3299 °N -89.1176 °W	Method Code: GPS008
NE NW or Govt Lot #:	Section: 1 — Township: 21 N — Range: 11 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S	T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	39

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E NEW DRILLERS PIPE 18.97 LBS/FT ASTM A-53 WHEATLAND	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	5X48X12 STAINLESS STEEL TELESCOPTIC	35	39

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 21 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJC	6105	02-26-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		64	POWTS dispersal component (soil absorption unit or mound)		66

Comment:

Created On: 02-26-2023 Updated On: 07-05-2023 Review Status: APPROVED