Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ349

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLINK, CHRISTOPHER	Phone #: (920)722-3368
Mailing Address: 1825 SILVERCREST DR	
City: APPLETON	State: WI — Zip Code: 54911
County: Marinette	Co. Permit #:
Notification #: 9857266301	Completed: 05-09-2025
Well Constructor (Business Name): KLEIMAN PUMP & WELL DRILLING INC	Lic. #: 575
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of PEMBINE	Fire # (if avail.): 6213
Street Address or Road Name and Number: CEMETERY RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.62426 °N -87.90083 °W	Method Code: GPS008

NW	NE	Section	Township	Range
or Govt Lot #		5	36 N	21 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private, non-potable — Borehole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY	Surface	20
T	A	Y	G	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL G-W/GRAVEL/STONES	20	23
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY	23	95
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY	95	100
T	A	Y	G	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL G-W/GRAVEL/STONES	100	104
T	A	Y	S	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL S-SANDY	104	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97, A-53, WHEATLAND, WELDED.	Surface	52
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	16 SLOT WIRE WRAPPED, STAINLESS STEEL	102	105

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	102	4 S

9. Static Water Level	11. Well Is
29 ft. below ground surface	24 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 102 ft. below surface	Disinfected ? Yes
Pumping at 10 GP H for 1 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK	6720	05-22-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CB	9191	05-22-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	81

Comment:

Created On: 05-22-2025 Updated On: 10-15-2026 Review Status: APPROVED