Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ350

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCGREGOR, HOLLY	Phone #: (312)771-7267
Mailing Address: 2216 EAGLES SUMMIT	
City: STEVENS POINT	State: WI / Zip Code: 54482
County: Florence	Co. Permit #:
Notification #: 9859106401	Completed: 06-02-2025
Well Constructor (Business Name): KLEIMAN PUMP & WELL DRILLING INC	Lic. #: 575
Facility ID # (Public Wells):	Well Plan Approval #:
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of FLORENCE				Fire # (if avail.): 1613
Street Address or Road Name and Number: GRANT LANE				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9061 °N -88.14115 °W				Method Code: GPS008
SE SE or Govt Lot #	Section: 29	Township: 40 N	Range: 19 E	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: OLD WELL LOCATED WHERE NEW HOME WAS TO BE BUILT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	Z		T-TAN/BROWN H-HARD/FIRM Z-CLAY & GRAVEL	Surface	2
K	M	Z		K-BLACK M-MEDIUM Z-CLAY & GRAVEL	2	6
T	N	X		T-TAN/BROWN N-FINE X-SAND & CLAY	6	19
T	Q	K	S	T-TAN/BROWN Q-CAVING K-COBBLES/BOULDERS S-SANDY	19	20
T	X	X		T-TAN/BROWN X-LENSED/STREAKED/LAYERED X-SAND & CLAY	20	35
T	X	G		T-TAN/BROWN X-LENSED/STREAKED/LAYERED G-GRAVEL/STONES	35	43
G	E	G		G-GRAY E-CLEAN G-GRAVEL/STONES	43	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, A53, WHEATLAND, WELDED	Surface	43
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	TELESCOPING W/ K PACKER, PLATE BOTTOM, STAINLESS STEEL	43	46

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	43	2 S

9. Static Water Level	11. Well Is
3 ft. below ground surface	36 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 42 ft. below surface	Disinfected ? Yes
Pumping at 20 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? Yes

WAS ALREADY ABANDONED LAST YEAR, SEE NOTATIONS ABOVE.

Filled & Sealed Well(s) as needed? Yes

WAS ALREADY ABANDONED LAST YEAR, SEE NOTATIONS ABOVE.

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK	6720	07-02-2025
Drill Rig Operator	Lic or Reg #	Date Signed
WB	6054	06-02-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		70

Comment: WATER SAMPLING MAY BE DELAYED DUE TO CIRCUMSTANCES BEYOND OUR CONTROL.

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		

Created On: 07-02-2025 Updated On: 10-15-2026 Review Status: APPROVED