# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* AAZ351

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: JOHN, ELLIS | Phone #: (715)589-4417 |
| Mailing Address: 1528 POINT BRAY RD | |
| City: FLORENCE | State: WI — Zip Code: 54121 |
| County: Florence | Co. Permit #: |
| Notification #: 10009682101 | Completed: 09-19-2025 |
| Well Constructor (Business Name): KLEIMAN PUMP & WELL DRILLING INC | Lic. #: 575 |
| Facility ID # (Public Wells): | |
| Address: PO BOX 704<br>IRON MOUNTAIN MI 49801-0704 | |
| Well Plan Approval #: | |
| Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: |
| Specific Capacity: 0.4 | |

**1. Well Location**

| | |
|---|---|
| Town of FLORENCE | Fire # (if avail.): 1528 |
| Street Address or Road Name and Number: 1528 POINT BRAY RD | |
| Subdivision Name: | Lot #: — Block #: |
| Latitude / Longitude in Decimal Degree (DD): 45.8861 °N -88.1371 °W | Method Code: GPS008 |

| SW | NW | Section | Township | Range |
|---|---|---|---|---|
| or Govt Lot # | | 4 | 39 N | 19 E |

**2. Well Type** New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

**3. Well serves** 1 # of HOME

Private,potable — Borehole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 83 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| Yes | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| T | N | G | S | T-TAN/BROWN N-FINE G-GRAVEL/STONES S-SANDY | Surface | 75 |
| T | E | S | S | T-TAN/BROWN E-CLEAN S-SAND S-SANDY | 75 | 83 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | STEEL, 18.97, A-53, WHEATLAND, WELDED. | Surface | 79 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 6 | 12 SLOT WIRE WRAPPED, STAINLESS STEEL | 79 | 83 |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | 79 | 5 S |

**9. Static Water Level**

35 ft. below ground surface

**10. Pump Test**

Pumping level 83 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

**11. Well Is**

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| EK | 6720 | 10-23-2025 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| CB | 9191 | 10-23-2025 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance |
|---|---|---|
| Sewer - Building Sanitary | > | 52 |

Comment:

Created On: 10-23-2025 Updated On: 11-28-2025 Review Status: APPROVED