Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ352

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PARKINSON, KATHLYN	Phone #: (906)779-5859
Mailing Address: 1001 E MAIN ST	
City: IRON MOUNTAIN	State: MI / Zip Code: 49801
County: Florence	Co. Permit #: MI / Notification #: 9805447801 / Completed: 10-16-2025
Well Constructor (Business Name): KLEIMAN PUMP & WELL DRILLING INC	Lic. #: 575 / Facility ID # (Public Wells):
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 0

1. Well Location

Town of AURORA	Fire # (if avail.): 1528
Street Address or Road Name and Number: P.O. BOX 704	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.76608 °N -88.16489 °W	Method Code: GPS008
NE SE or Govt Lot #:	Section: 18 / Township: 38 N / Range: 19 E

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable — Borehole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	Y	S	T-TAN/BROWN N-FINE Y-SAND & GRAVEL S-SANDY	Surface	12
T	A	Z	C	T-TAN/BROWN A-COARSE Z-CLAY & GRAVEL C-CLAYEY	12	72
E	H	B	Q	E-GREEN H-HARD/FIRM B-BASALT OR TRAP ROCK Q-W/GRANITE	72	105
I	H	R	Q	I-WHITE H-HARD/FIRM R-QUARTZITE Q-W/GRANITE	105	115
E	H	Q	Q	E-GREEN H-HARD/FIRM Q-GRANITE Q-W/GRANITE	115	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97, A-53, WHEATLAND, WELDED.	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	70	4 S

9. Static Water Level
67 ft. below ground surface

10. Pump Test
Pumping level 300 ft. below surface
Pumping at 3 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK	6720	10-23-2025
Drill Rig Operator	Lic or Reg #	Date Signed
CB	9191	10-23-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		

Comment: SEPTIC NOT IN YET.

Created On: 10-23-2025 Updated On: 11-28-2025 Review Status: APPROVED