

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAZ352		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner PARKINSON, KATHLYN				Phone # (906)779-5859		1. Well Location				Fire # (if avail.)		
Mailing Address 1001 E MAIN ST						Town of AURORA				1528		
City IRON MOUNTAIN				State MI Zip Code 49801		Street Address or Road Name and Number P.O. BOX 704						
County Florence		Co. Permit # MI		Notification # 9805447801		Completed 10-16-2025		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) KLEIMAN PUMP & WELL DRILLING INC				Lic. # 575		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.76608 °N -88.16489 °W			Method Code GPS008	
Address PO BOX 704 IRON MOUNTAIN MI 49801-0704				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 18 38 N 19 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in				
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?						
Private,potable Borehole				Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		
6		Surface		300		No Rotary - Mud Circulation		No		T N Y S T-TAN/BROWN N-FINE Y-SAND & GRAVEL S-SANDY		
						Yes Rotary - Air		No		T A Z C T-TAN/BROWN A-COARSE Z-CLAY & GRAVEL C-CLAYEY		
						No Rotary - Air & Foam		No		E H B Q E-GREEN H-HARD/FIRM B-BASALT OR TRAP ROCK Q-W/GRANITE		
						No Drill-Through Casing Hammer				I H R Q I-WHITE H-HARD/FIRM R-QUARTZITE Q-W/GRANITE		
						No Reverse Rotary				E H Q Q E-GREEN H-HARD/FIRM Q-GRANITE Q-W/GRANITE		
						No Cable-tool Bit ___ in. dia...		No				
						No Dual Rotary		No				
						No Temp. Outer Casing ___ in. dia						
						No Removed? ___ depth ft. (If NO explain on back side)						
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		
6		STEEL, 18.97, A-53, WHEATLAND, WELDED.				Surface		70		67 ft. below ground surface		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is		
										24 in. above grade		
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test		
GRANULAR BENTONITE				Surface		70		4 S		Developed ? Yes		
Pumping level 300 ft. below surface												
Pumping at 3 GP M for 1 Hrs.												
Pumping Method ? Airlift												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller												
Lic #				Date Signed								
EK				6720				10-23-2025				
Drill Rig Operator												
Lic or Reg #				Date Signed								
CB				9191				10-23-2025				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		

Comment: SEPTIC NOT IN YET.

Created On: 10-23-2025

Updated On: 11-28-2025

Review Status: APPROVED