Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAZ927

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: RICKERT, EVAN	Phone #: (847) 34-3886
Mailing Address: 35350 52ND STREET	
City: BURLINGTON	State: WI — Zip Code: 53105
County: Kenosha	Co. Permit #: — Notification #: 9031500601 — Completed: 02-01-2023
Well Constructor (Business Name): BEACH PUMP & WELL SERVICE INC	Lic. #: 6124 — Facility ID # (Public Wells):
Address: 10453 W BOYCE LN, BEACH PARK IL 60087	Well Plan Approval #: — Approval Date (mm-dd-yyyy): 01-11-2023
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 6

1. Well Location
City of KENOSHA
Fire # (if avail.):
Street Address or Road Name and Number: 35350 52ND STREET
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.58998 °N -88.23954 °W — Method Code: SCR006
SE NW or Govt Lot #: — Section: 34 — Township: 2 N — Range: 19 E

2. Well Type New Well
of previous unique well #: — constructed in: 2023
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
5	9	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 5in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	X-SAND & CLAY	Surface	12
G	G-GRAVEL/STONES	12	36
Y	Y-SAND & GRAVEL	36	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ASTM A-53 BT/C WHEATLAND - COUPLING ASSEMBLY	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	5" TELE STAINLESS SLOT # 15, SAND & GRAVEL	35	38

7. Grout or Other Sealing Material
Method GROUT DISPLACEMENT (PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	9	3

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 18 ft. below surface
Pumping at 12 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KB	6123	02-06-2023
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KB		02-09-2023

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-09-2023 Updated On: 08-25-2023 Review Status: APPROVED