Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABC922

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PROPERTY LOGIC III LLC	Phone #
Mailing Address: P.O. BOX 2132	
City: LA CROSSE	State: WV Zip Code: 54602

County	Co. Permit #	Notification #	Completed
La Crosse	2024078	9761613201	02-25-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HOLLER, WAYNE	4668	

Address: HOLLER PLUMBING & WELL DRILLING
N2995 SMITH VALLEY RD
LA CROSSE WI 54601-2935

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.8

1. Well Location

Town of ONALASKA

Fire # (if avail.): N5411

Street Address or Road Name and Number: SOBKOWIAK RD

Subdivision Name	Lot #	Block #
	2	

Latitude / Longitude in Decimal Degree (DD): 43.91746 °N -91.20878 °W

Method Code: GPS008

NW SW or Govt Lot #	Section	Township	Range
	27	17 N	7 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 2 # of DUPLEX

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	130

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	C	S	T-TAN/BROWN S-SOFT/LOOSE C-CLAY S-SANDY	Surface	60
Y	N	S	S	Y-YELLOW N-FINE S-SAND S-SANDY	60	77
G	H	N	N	G-GRAY H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	77	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53B 280 WALL WHEATLAND USA PLAIN END WELD	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 18 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		4 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	4668	02-28-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		60
POWTS dispersal component (soil absorption unit or mound)		95
Building Drain - Sanitary		45
Landfill	>	1200

Comment:

Created On: 02-25-2025 Updated On: 03-07-2025 Review Status: APPROVED