

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABO841		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KNOP JOHN				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W11066 BENNOR RD.				City BRUCE		State WI		Zip Code 54819		Town of ATLANTA	
Street Address or Road Name and Number W11072 BENNOR RD.				Subdivision Name		Lot #		Block #		W11072	
County Rusk		Co. Permit #		Notification # 9240390201		Completed 08-30-2023		Latitude / Longitude in Decimal Degree (DD) 45.5408 °N -91.245 °W		Method Code SCR002	
Well Constructor (Business Name) ATWOOD, THOMAS				Lic. # 15		Facility ID # (Public Wells)		NW SE Section Township Range or Govt Lot # 4 35 N 7 W		Well Plan Approval #	
Address ATWOOD WELL DRILLING W11501 TRAILS END RD BRUCE WI 54819-9722				Approval Date (mm-dd-yyyy)		2. Well Type New Well		of previous unique well #		constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?		Construction Type Drilled		Heat Exchange ___ # of drillholes	
3. Well serves # of HOME				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No		Private, potable Nontransient	
4. Potential Contamination Sources - ON REVERSE SIDE				5. Drillhole Dimensions and Construction Method		8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
6		Surface		44		No Rotary - Mud Circulation		No		T Q S T-TAN/BROWN Q-CAVING S-SAND	
						No Rotary - Air		No		T A G T-TAN/BROWN A-COARSE G-GRAVEL/STONES	
						No Rotary - Air & Foam		No		T W S T-TAN/BROWN W-WATER BEARING S-SAND	
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen				9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)		27 ft. below ground surface		16 in. above grade	
6		ASTMA53, 19LBS FT, WELDED NTP		Surface		42		10. Pump Test		Developed ? Yes	
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)		Pumping level 37 ft. below surface		Disinfected ? Yes	
4		CONTINUOUS SLOT SS #12		42		44		Pumping at 5 GP M for 2 Hrs.		Capped ? Yes	
7. Grout or Other Sealing Material				12. Notified Owner of need to fill & seal ?				No			
Method MOUNDED				Filled & Sealed Well(s) as needed?				No			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller		Lic #	
GRANULAR BENTONITE		Surface				2 S		TAA		15	
								Drill Rig Operator		Lic or Reg #	
										Date Signed	
										Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		75

Comment:

Created On: 09-25-2023

Updated On: 10-03-2023

Review Status: APPROVED