Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABO841

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KNOP JOHN	Phone #
Mailing Address: W11066 BENNOR RD.	
City: BRUCE	State: WI — Zip Code: 54819
County: Rusk	Co. Permit #:
Notification #: 9240390201	Completed: 08-30-2023
Well Constructor (Business Name): ATWOOD, THOMAS	Lic. #: 15
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: ATWOOD WELL DRILLING W11501 TRAILS END RD BRUCE WI 54819-9722	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of ATLANTA	Fire # (if avail.): W11072
Street Address or Road Name and Number: W11072 BENNOR RD.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.5408 °N -91.245 °W	Method Code: SCR002

NW	SE	Section	Township	Range
or Govt Lot #		4	35 N	7 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of HOME

Private,potable — Nontransient

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	30
T	A	G		T-TAN/BROWN A-COARSE G-GRAVEL/STONES	30	42
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	42	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53, 19LBS FT, WELDED NTP	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	CONTINUOS SLOT SS #12	42	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 5 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAA	15	09-25-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		75

Comment:

Created On: 09-25-2023 Updated On: 10-15-2026 Review Status: APPROVED