Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABP701

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: GEISLER DANIEL	Phone #
Mailing Address: N4731 ZEBRO ROAD	
City: BRUCE	State: WI — Zip Code: 54819

County	Co. Permit #	Notification #	Completed
Rusk		9279887501	10-05-2023

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ATWOOD, THOMAS	15	

Address: ATWOOD WELL DRILLING W11501 TRAILS END RD, BRUCE WI 54819-9722

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

3. Well serves # of HOME & BARN
Private,potable — Nontransient
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of STUBBS	Fire # (if avail.) N4731

Street Address or Road Name and Number: N4731 ZEBRO ROAD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.4571 °N -91.3139 °W	SCR002

SW NW or Govt Lot #	Section	Township	Range
	1	34 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	V	C		K-BLACK V-NON-CAVING C-CLAY	Surface	6
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	6	16
T	Q	Z		T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL	16	38
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	38	41

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53, 19LBS FT, WELDED NTP	Surface	38
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	CONTINUOS SLOT SS #15	38	41

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 32 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAA	15	10-21-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		40	POWTS dispersal component (soil absorption unit or mound)		100
			Silo/Storage Tube		125

Comment:

Created On: 10-21-2023 Updated On: 10-15-2026 Review Status: APPROVED