Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABQ977

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: POBLOCKI PAUL			Phone #
Mailing Address: N21 W29844 GLEN COVE RD			
City: PEWAUKEE	State: WI	Zip Code: 53072	
County: Waukesha	Co. Permit #:	Notification #: 9349506501	Completed: 12-06-2023

Well Constructor (Business Name): ANHALT WELL DRLG & PUMP INC	Lic. #: 6726	Facility ID # (Public Wells):	
Address: PO BOX 55 N509 HWY 67 ASHIPPUN WI 53003-0352		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

1. Well Location

Town of DELAFIELD

Fire # (if avail.):

Street Address or Road Name and Number: N21 W29844 GLEN COVE RD

Subdivision Name: GLEN COVE PARK	Lot #: 56	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.0591 °N -88.341 °W				Method Code: GPS008
NW or Govt Lot #: NW	Section: 23	Township: 7 N	Range: 18 E	

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: TEAR DOWN

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	200

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	22
	Q	H		Q-CAVING H-SHALE	22	52
	H	H		H-HARD/FIRM H-SHALE	52	198
		L		L-LIMESTONE/DOLOMITE	198	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A 53B 18.97 LBS/FT STEEL WELDED	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

NOT CONTRACTED

13. Constructor / Supervisory Driller	Lic #	Date Signed
AA	6261	01-10-2024
Drill Rig Operator	Lic or Reg #	Date Signed
RD	124	01-10-2024

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		46	Sewer - Building Sanitary		175

Comment:

Created On: 12-07-2023 Updated On: 02-09-2024 Review Status: APPROVED