

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABQ977		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner POBLOCKI PAUL				Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N21 W29844 GLEN COVE RD				City PEWAUKEE		State WI		Zip Code 53072		Town of DELAFIELD			
County Waukesha				Co. Permit #		Notification # 9349506501		Completed 12-06-2023		Street Address or Road Name and Number N21 W29844 GLEN COVE RD			
Well Constructor (Business Name) ANHALT WELL DRLG & PUMP INC				Lic. # 6726		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.0591 °N -88.341 °W		Method Code GPS008			
Address PO BOX 55 N509 HWY 67 ASHIPPUN WI 53003-0352				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 23 7 N 18 E		2. Well Type Replacement					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ? TEAR DOWN					
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Private, potable				Hicap Potable ? No									
Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		
6	Surface	200	No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						Y	Y-SAND & GRAVEL	Surface	22	
									Q	H	Q-CAVING H-SHALE	22	52
									H	H	H-HARD/FIRM H-SHALE	52	198
										L	L-LIMESTONE/DOLOMITE	198	200
6. Casing, Liner, Screen													
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)								
6	WHEATLAND A 53B 18.97 LBS/FT STEEL WELDED			Surface	52								
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)								
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement								
GRANULAR BENTONITE			Surface										
8. Geology													
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 180 ft. below surface													
Pumping at 20 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? Yes													
NOT CONTRACTED													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
AA			6261 01-10-2024										
Drill Rig Operator			Lic or Reg # Date Signed										
RD			124 01-10-2024										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		46	Sewer - Building Sanitary		175

Comment:

Created On: 12-07-2023

Updated On: 02-09-2024

Review Status: APPROVED