Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABR235

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: COBBLESTONE BUILDERS	Phone #
Mailing Address: N88W16791 MAIN ST UNIT 1	
City: MENOMONEE FALLS	State: WI — Zip Code: 53051

County	Co. Permit #	Notification #	Completed
Washington		9357568401	12-14-2023

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ANHALT WELL DRLG & PUMP INC	6726	

Address: PO BOX 55 N509 HWY 67
ASHIPPUN WI 53003-0352

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.1

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of HARTFORD

Fire # (if avail.)

Street Address or Road Name and Number
6168 POWDER HILL CT

Subdivision Name	Lot #	Block #
KETTLE RIDGE		

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.3149	°N	-88.3404	°W	SCR002

NE SE or Govt Lot #	Section	Township	Range
	22	10 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	89

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	18
G		Z		G-GRAY Z-CLAY & GRAVEL	18	76
G		Y	S	G-GRAY Y-SAND & GRAVEL S-SANDY	76	87
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	87	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97 LBS/FT STEEL WELDED	Surface	89
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	25 SLOT STAINLESS	86	89

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AA	6261	09-01-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		60

Comment:

Created On: 12-15-2023 Updated On: 10-15-2026 Review Status: APPROVED