

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABR235		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A								
Property Owner COBBLESTONE BUILDERS						Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address N88W16791 MAIN ST UNIT 1						Town of HARTFORD						Street Address or Road Name and Number 6168 POWDER HILL CT						
City MENOMONEE FALLS				State WI		Zip Code 53051												
County Washington		Co. Permit #		Notification # 9357568401		Completed 12-14-2023		Subdivision Name KETTLE RIDGE			Lot # Block #							
Well Constructor (Business Name) ANHALT WELL DRLG & PUMP INC				Lic. # 6726		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3149 °N -88.3404 °W			Method Code SCR002					
Address PO BOX 55 N509 HWY 67 ASHIPPUN WI 53003-0352				Well Plan Approval #				NE SE Section Township Range or Govt Lot # 22 10 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
				Approval Date (mm-dd-yyyy)														
Hicap Permanent Well #		Common Well #		Specific Capacity 0		3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ? No												
4. Potential Contamination Sources - ON REVERSE SIDE																		
5. Drillhole Dimensions and Construction Method																		
Dia. (in.) 6		From (ft.) Surface		To (ft.) 89		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology								
No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)		T Y		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) Surface		To (ft.) 18		T-TAN/BROWN Y-SAND & GRAVEL G-GRAY Z-CLAY & GRAVEL G-GRAY Y-SAND & GRAVEL S-SANDY T-TAN/BROWN Y-SAND & GRAVEL								
		G Z		18		76												
		G Y S		76		87												
		T Y		87		89												
		6. Casing, Liner, Screen						9. Static Water Level			11. Well Is							
		Dia. (in.) 6		Material, Weight, Specification WHEATLAND A53B 18.97 LBS/FT STEEL WELDED		From (ft.) Surface		To (ft.) 89		18 ft. below ground surface			18 in. above grade					
		Dia. (in.) 5		Screen type, material & slot size 25 SLOT STAINLESS		From (ft.) 86		To (ft.) 89		10. Pump Test			Developed ? Yes Disinfected ? Yes Capped ? Yes					
		Pumping level 45 ft. below surface		Pumping at 30 GP M for 1 Hrs.			Pumping Method ? Airlift			12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No								
7. Grout or Other Sealing Material						13. Constructor / Supervisory Driller			Lic # 6261				Date Signed 09-01-2025					
Method MOUNDED		Kind of Sealing Material GRANULAR BENTONITE		From (ft.) Surface		To (ft.)		# Sacks Cement		Drill Rig Operator			Lic or Reg #			Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		60

Comment:

Created On: 12-15-2023

Updated On: 10-09-2025

Review Status: APPROVED