Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABR394

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COBBLESTONE BUILDERS	Phone #
Mailing Address: N88 W16791 MAIN ST UNIT #1	
City: MENOMONEE FALLS	State: WI — Zip Code: 53051

County	Co. Permit #	Notification #	Completed
Washington		9373351101	12-20-2023

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ANHALT WELL DRLG & PUMP INC	6726	

Address: PO BOX 55 N509 HWY 67
ASHIPPUN WI 53003-0352

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.2

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of HARTFORD

Fire # (if avail.)

Street Address or Road Name and Number: 3412 LAKE DR

Subdivision Name	Lot #	Block #
KETTLE RIDGE		

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.3149 °N -88.3411 °W	SCR002

NE SE or Govt Lot #	Section	Township	Range
	22	10 N	18 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	91

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	38
G		Z		G-GRAY Z-CLAY & GRAVEL	38	81
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	81	91

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B 18.97LBS/FT STEEL WELDED	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	25 SLOT STAINLESS	88	91

7. Grout or Other Sealing Material

Method MOUNDED

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AA	6261	09-01-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 12-21-2023 Updated On: 10-15-2026 Review Status: APPROVED