

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABR394		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner COBBLESTONE BUILDERS					Phone #		1. Well Location Fire # (if avail.) Town of HARTFORD Street Address or Road Name and Number 3412 LAKE DR				Subdivision Name KETTLE RIDGE		Lot # Block #		
Mailing Address N88 W16791 MAIN ST UNIT #1															
City MENOMONEE FALLS			State WI		Zip Code 53051										
County Washington		Co. Permit #		Notification # 9373351101		Completed 12-20-2023									
Well Constructor (Business Name) ANHALT WELL DRLG & PUMP INC				Lic. # 6726		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.3149 °N -88.3411 °W				Method Code SCR002			
Address PO BOX 55 N509 HWY 67 ASHIPPUN WI 53003-0352				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SE		Section 22		Township 10 N		Range 18 E	
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		91		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		Y		T-TAN/BROWN Y-SAND & GRAVEL				Surface		38					
G		Z		G-GRAY Z-CLAY & GRAVEL				38		81					
T		Y		T-TAN/BROWN Y-SAND & GRAVEL				81		91					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		A53B 18.97LBS/FT STEEL WELDED				Surface		91							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		25 SLOT STAINLESS				88		91							
7. Grout or Other Sealing Material															
Method MOUNDED															
9. Static Water Level															
19 ft. below ground surface															
10. Pump Test															
Pumping level 45 ft. below surface															
Pumping at 30 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
AA				6261				09-01-2025							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-21-2023

Updated On: 10-09-2025

Review Status: APPROVED