

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABR452		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																															
Property Owner BRAD MARTHLER					Phone #		1. Well Location Fire # (if avail.) Town of WEST POINT W14109 Street Address or Road Name and Number W14109 THERESA LANE																																		
Mailing Address 102 DODGE DRIVE																																									
City SMYRNA			State DE		Zip Code 19977		Subdivision Name Lot # Block #																																		
County Columbia		Co. Permit #		Notification # 9373518201		Completed 12-22-2023																																			
Well Constructor (Business Name)			Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code																														
WEBSTER BRAD & SONS DRILLING INC			6574				43.3299 °N -89.7003 °W				GPS008																														
Address 415 N MAIN ST POYNETTE WI 53955			Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NE		Section Township		Range																														
							or Govt Lot #		19 10 N		7 E																														
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																																			
				0																																					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No																																					
4. Potential Contamination Sources - ON REVERSE SIDE																																									
5. Drillhole Dimensions and Construction Method																																									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...																															
6		Surface		101		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td></td><td>C</td><td>S</td><td>C-CLAY S-SANDY</td><td>Surface</td><td>3</td> </tr> <tr> <td></td><td>K</td><td>S</td><td>K-COBBLER/BOULDERS S-SANDY</td><td>3</td><td>9</td> </tr> <tr> <td></td><td>Y</td><td>C</td><td>Y-SAND & GRAVEL C-CLAYEY</td><td>9</td><td>22</td> </tr> <tr> <td></td><td>Y</td><td></td><td>Y-SAND & GRAVEL</td><td>22</td><td>85</td> </tr> <tr> <td>E</td><td>Y</td><td></td><td>E-CLEAN Y-SAND & GRAVEL</td><td>85</td><td>101</td> </tr> </table>			C	S	C-CLAY S-SANDY	Surface	3		K	S	K-COBBLER/BOULDERS S-SANDY	3	9		Y	C	Y-SAND & GRAVEL C-CLAYEY	9	22		Y		Y-SAND & GRAVEL	22	85	E	Y		E-CLEAN Y-SAND & GRAVEL	85	101
	C	S	C-CLAY S-SANDY	Surface	3																																				
	K	S	K-COBBLER/BOULDERS S-SANDY	3	9																																				
	Y	C	Y-SAND & GRAVEL C-CLAYEY	9	22																																				
	Y		Y-SAND & GRAVEL	22	85																																				
E	Y		E-CLEAN Y-SAND & GRAVEL	85	101																																				
6. Casing, Liner, Screen																																									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																															
6		MARUICHI LEAVITT A53B PE .280 WALL				Surface		98																																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																																	
5		ALLOY MACHINE WORKS STAINLESS 15 SLOT SCREEN WITH 5"X6" K-PACKER ON TOP				98		101																																	
7. Grout or Other Sealing Material																																									
Method MOUNDED																																									
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No																																
GRANULAR BENTONITE			Surface		98		3 S																																		
13. Constructor / Supervisory Driller																																									
RW			Lic #		Date Signed																																				
Drill Rig Operator			Lic or Reg #		Date Signed																																				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	85	POWTS dispersal component (soil absorption unit or mound)	>	54
POWTS holding component (also known as holding tank)	>	75	Building Drain - Sanitary	>	14
			Sewer - Building Sanitary	>	85

Comment:

Created On: 12-26-2023

Updated On: 02-05-2024

Review Status: APPROVED