Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABR452

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAD MARTHLER	Phone #
Mailing Address: 102 DODGE DRIVE	
City: SMYRNA	State: DE — Zip Code: 19977
County: Columbia	Co. Permit #: — Notification #: 9373518201 — Completed: 12-22-2023
Well Constructor (Business Name): WEBSTER BRAD & SONS DRILLING INC	Lic. #: 6574 — Facility ID # (Public Wells):
Address: 415 N MAIN ST, POYNETTE WI 53955	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of WEST POINT	Fire # (if avail.): W14109
Street Address or Road Name and Number: W14109 THERESA LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.3299 °N -89.7003 °W	Method Code: GPS008
SE NE or Govt Lot #: — Section: 19 — Township: 10 N — Range: 7 E	

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	101

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	C-CLAY S-SANDY	Surface	3
		K	S	K-COBBLES/BOULDERS S-SANDY	3	9
		Y	C	Y-SAND & GRAVEL C-CLAYEY	9	22
		Y		Y-SAND & GRAVEL	22	85
	E	Y		E-CLEAN Y-SAND & GRAVEL	85	101

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARUICHI LEAVITT A53B PE .280 WALL	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ALLOY MACHINE WORKS STAINLESS 15 SLOT SCREEN WITH 5"X6" K-PACKER ON TOP	98	101

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	98	3 S

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW	6890	12-26-2023
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	85
POWTS holding component (also known as holding tank)	>	75
POWTS dispersal component (soil absorption unit or mound)	>	54
Building Drain - Sanitary	>	14
Sewer - Building Sanitary	>	85

Comment:

Created On: 12-26-2023 Updated On: 10-15-2026 Review Status: APPROVED