

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABR632		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner GARY CHARLES					Phone #			1. Well Location				Fire # (if avail.)							
Mailing Address 3770 HWY C								Town of POLK											
City WEST BEND					State WI		Zip Code 53095		Street Address or Road Name and Number				3770 HWY C						
County Washington		Co. Permit #		Notification # 9374211701		Completed 01-04-2024		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) ANHALT WELL DRLG & PUMP INC				Lic. # 6726		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.3387 °N -88.226 °W				Method Code SCR002							
Address PO BOX 55 N509 HWY 67 ASHIPPUN WI 53003-0352				Well Plan Approval #		NE NE		Section 15		Township 10 N		Range 19 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type Replacement												
						of previous unique well # constructed in													
						Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes						POINT WELL													
3. Well serves 1 # of HOME						Construction Type Drilled													
Private, potable						Hicap Well ? No													
Hicap Property ? No						Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		168		No Rotary - Mud Circulation		No		Y		Y-SAND & GRAVEL		Surface		31			
						No Rotary - Air		No		Z S		Z-CLAY & GRAVEL S-SANDY		31		40			
						No Rotary - Air & Foam		No		X		X-SAND & CLAY		40		85			
						Yes Drill-Through Casing Hammer				C M		C-CLAY M-SILTY		85		118			
						No Reverse Rotary				Z		Z-CLAY & GRAVEL		118		162			
						No Cable-tool Bit ___ in. dia...		No		Y		Y-SAND & GRAVEL		162		168			
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is					
6		WHEATLAND A53B 18.97 LBS/FT STEEL WELDED				Surface		168		16 ft. below ground surface				18 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes					
										Pumping level 45 ft. below surface				Disinfected ? Yes					
										Pumping at 25 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes							
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		PUMP INSTALLER TO DO				Filled & Sealed Well(s) as needed? No					
GRANULAR BENTONITE				Surface						PUMP INSTALLER TO DO									
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												AA				6261		09-01-2025	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		53	POWTS dispersal component (soil absorption unit or mound)		85

Comment:

Created On: 01-05-2024

Updated On: 10-09-2025

Review Status: APPROVED