Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABR633

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CAROL AND KURT LANING	Phone #
Mailing Address: 21473 N. PRESTWICK DR	
City: BARRINGTON	State: IL — Zip Code: 60010

County	Co. Permit #	Notification #	Completed
Dane	00212	9374816701	01-05-2024

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WEBSTER BRAD & SONS DRILLING INC	6574	

Address: 415 N MAIN ST, POYNETTE WI 53955

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.2

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of VERONA

Fire # (if avail.): 2251

Street Address or Road Name and Number: 2251 PRAIRIE VISTA DR

Subdivision Name	Lot #	Block #
TWIN ROCK	15	

Latitude / Longitude in Decimal Degree (DD): 42.9776 °N -89.5984 °W — Method Code: GPS008

NW SW or Govt Lot #	Section	Township	Range
	19	6 N	8 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
12.3	Surface	21
8.8	21	180
6	180	244

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 21depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F	C	F-FILL C-CLAYEY	Surface	4
		Z		Z-CLAY & GRAVEL	4	9
T		L	H	T-TAN/BROWN L-LIMESTONE/DOLOMITE H-SHALEY	9	24
	H	L		H-HARD/FIRM L-LIMESTONE/DOLOMITE	24	208
	H	N		H-HARD/FIRM N-SANDSTONE	208	235
	H	L	S	H-HARD/FIRM L-LIMESTONE/DOLOMITE S-SANDY	235	244

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B PE .280 WALL	Surface	180
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	180	35 S

9. Static Water Level

77 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 35 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW	6890	01-08-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	100	Building Drain - Sanitary	>	40
POWTS dispersal component (soil absorption unit or mound)	>	120	Sewer - Building Sanitary	>	75
			Ditch or Culvert	>	35

Comment:

Created On: 01-05-2024 Updated On: 10-15-2026 Review Status: APPROVED