Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABS610

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CUNNINGHAM, CHUCK	Phone #
Mailing Address: SANDY POINT	
City: PARK FALLS	State: WI — Zip Code: 54552
County: Price	Co. Permit #:
Notification #: 9280116004	Completed: 10-30-2023
Well Constructor (Business Name): HOLT, JOHN A	Lic. #: 250
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.4	

1. Well Location

Town of EISENSTEIN	Fire # (if avail.): W7218
Street Address or Road Name and Number: SANDY POINT	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9594 °N -90.41824 °W	Method Code: SCR006

NW	SW	Section	Township	Range
or Govt Lot #		7	40 N	1 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CAMPER/HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	G-GRAVEL/STONES	Surface	30
P	P-HARDPAN	30	100
Y	Y-SAND & GRAVEL	100	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B PE	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

54 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 10 GP M for 8 Hrs.

Pumping Method ? Other

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	250	02-29-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		25	POWTS dispersal component (soil absorption unit or mound)		50

Comment: JEFFREY HOLT SIGNED AS RIG OPERATOR

3/4/24 COORDINATES AND ADDRESS ADDED BY DNR. NOT PROVIDED BY WELL DRILLER

Created On: 03-04-2024 Updated On: 03-26-2024 Review Status: APPROVED