Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABS612

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GORENSCHEK, RICH			Phone #
Mailing Address: W9234 GRANT RD			
City: BUTTERNUT	State: WI	Zip Code: 54514	
County: Price	Co. Permit #:	Notification #: 9280116001	Completed: 10-03-2023

Well Constructor (Business Name): HOLT, JOHN A	Lic. #: 250	Facility ID # (Public Wells)	
Address: JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1	

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of LAKE

Fire # (if avail.): W9234

Street Address or Road Name and Number: GRANT

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.96112 °N -90.52742 °W	SCR006

SW	NW	Section	Township	Range
or Govt Lot #		8	40 N	1 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	57

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	55
		Y		Y-SAND & GRAVEL	55	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B PE	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS - 15	54	57

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 47 ft. below surface
Pumping at 5 GP M for 8 Hrs.
Pumping Method ? Other

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	250	02-29-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		25	POWTS dispersal component (soil absorption unit or mound)		75

Comment: JEFFREY HOLT SIGNED AS RIG OPERATOR

3/4/24 DNR ENTERED FIRE NUMBER AND COORDINATES - NOT PROVIDED BY WELL DRILLER

Created On: 03-04-2024 Updated On: 03-26-2024 Review Status: APPROVED