

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABS613		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LANZENDORF, TIM						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 11848 CO J						Town of LAKE											
City LODI						State WI		Zip Code 53553									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
Price				9280116002		10-03-2023											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
HOLT, JOHN A				250				45.88394 °N -90.54144 °W				SCR006					
						Well Plan Approval #		SW SE		Section		Township		Range			
Address JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310						Approval Date (mm-dd-yyyy)		or Govt Lot #		6		39 N		1 W			
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well									
						1.3		of previous unique well #				constructed in					
3. Well serves 1 # of CAMPER/HOME				Hicap Well ?		No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ?		No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		26						Y		Y-SAND & GRAVEL		Surface		26	
						No Rotary - Mud Circulation		No									
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface		20 in. above grade					
6		ASTM A53B PE				Surface		26		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 16 ft. below surface		Disinfected ? Yes					
										Pumping at 10 GP M for 8 Hrs.		Capped ? Yes					
										Pumping Method ? Other							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No			
Method												Filled & Sealed Well(s) as needed?		No			
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JH		250		02-29-2024	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		25

Comment:

JEFFREY HOLT SIGNED AS RIG OPERATOR

3/4/24 DNR ENTERED COORDINATES AND SECTION. NOT PROVIDED BY DRILLER

Created On: 03-04-2024**Updated On:** 03-26-2024**Review Status:** APPROVED